

Certificate of Analysis

Product Name: Deionized Water / Demineralized Water

Lot Number: EXAMPLE

Date of Manufacture: Thursday, March 21, 2013

Testing performed by:

Test	Units	Quality Spec	Product Results	Comments
Conductivity	μMho/cm	≤ 1 μMho/cm		
pH		6.0 – 8.0		
Sodium	ppm as Na	≤ 0.5 ppm		
Calcium	ppm as CaCO ₃	≤ 0.1 ppm		
Magnesium	ppm as CaCO ₃	≤ 0.1 ppm		
Iron	ppm as Fe	≤ 0.1 ppm		
Chloride	ppm as Cl	≤ 0.2 ppm		
Silica	ppm as SiO ₂	≤ 0.2 ppm		

IMPORTANT: All information provided is believed to be accurate and complete. The data provided is representative of the product quality on the date of analysis for the lot number indicated. This certificate of analysis may not include all of the constituents of the product. Persons using this information should make their own determination regarding its suitability for their particular application. This certificate of analysis shall not in any way limit or preclude the operation and effect of the applicable terms and conditions of sale.

This is a computer generated document. It is valid without signature.